

**The Philadelphia Parking Authority
701 Market Street, Suite 5400
Philadelphia, PA 19106**

**Bid No. 17-15
Replace Roofing Systems at Various Locations
Addendum Two**

To: See Email Distribution List
From: Mary Wheeler
Manager of Contract Administration
Date: February 2, 2018
No Pages: 1

This addendum is issued on February 2, 2018 after the question due date and before the bid due date to add, delete, modify, clarify and/or to respond to questions submitted by prospective offerors regarding the work included in the above referenced solicitation.

CLARIFICATIONS, CHANGES AND ADDITIONS TO THE BID DOCUMENTS

1. The Question Deadline has been extended until Wednesday, January 31, 2018 at 2:00 PM.
2. The Bid Due Date has been changed to Friday, February 9, 2018 at 2:00 PM.
3. Height restrictions for the garages are 6'-2" at Gallery Mall and 6'-7" at Old City.

QUESTIONS

1. **Question:** Can you provide some clarification on the edge metal specifications on this project. There is some discrepancy between what is described in the notes and what is shown in the drawings. Note 3 on drawing IVMF-A1 mentions coping where the corresponding detail drawing 11/IVMF-A2 shows snap on fascia. The same discrepancy exists between note 2 on drawing G-A1 and detail 6/G-A0.8. Also, detail 1/IVMF-A2 shows a different style gravel stop than the SecureEdge400 described in specifications section 075323 pg 5. Please clarify.

Response: Keyed Notes #3 on Drawing IVMF-A1 and #2 on Drawing G-A1 are revised to read, "Provide and install new parapet snap on fascia." Details 11/IVMF-A2 and 6/G-A0.8 are correct.

The correct Edging and Termination type for the gravel stops is indicated in Specification Section 07 53 23; 2.05.1.2 – Elastomeric Membrane Roofing as "Drip Edge". The gravel stop detail shown on Detail 1/IVMF-A2 slightly modifies Carlisle's "Sure-Seal Drip Edge" standard detail to provide a raised gravel stop.

2. **Question:** Please provide the size and gauge for the three goose neck vents at Essington Avenue.

Response: The three goose neck vents are shown on Detail 5/IVMF-A1 as sheet metal. Provide galvanized sheet metal. Refer to Specification Section 07 62 00; 2.02.A - Sheet Metal Flashing and Trim for gauge. Keyed Demolition Note #27 on Drawing IVMF-D1 identifies the curb size and the duct is estimated at 6 x 8 inches. Final duct size will be determined with shop drawings.

END OF ADDENDUM TWO